

CITY OF ROYAL OAK

2004 CONSUMERS ANNUAL REPORT ON WATER QUALITY

ATTENTION: THIS IS AN IMPORTANT REPORT ON WATER QUALITY AND SAFETY

The City of Royal Oak, The Southeastern Oakland County Water Authority and the Detroit Water and Sewerage Department (DWSD) are proud of the fine drinking water they supply and are honored to provide this report to you. The 2004 Consumers Annual Report on Water Quality shows the sources of our water, lists the results of our tests, and contains important information about water and health. We will notify you immediately if there is ever any reason for concern about our water. We are pleased to show you how we have surpassed water quality standards as mandated by the Environmental Protection Agency (EPA) and the State of Michigan Department of Environmental Quality (MDEQ).

About the System

The City of Royal Oak purchases water from the Southeastern Oakland County Water Authority (SOCWA) at sixteen locations. SOCWA provides Detroit water through its member distribution systems to a population of 220,000 within a 56 square mile area. Current members are: Berkley, Beverly Hills, Bingham Farms, Birmingham, Clawson, Huntington Woods, Lathrup Village, Pleasant Ridge, Royal Oak, Southfield and Southfield Township.

Your source water comes from the Detroit River (treated at the Northeast Plant), situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment to determine the susceptibility of potential contamination. The susceptibility rating is on a six-tiered scale from very low to high based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes were determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards.

If you would like to know more about this report please visit the Detroit Water and Sewerage Department's website at www.dwsd.org or contact Mary Lynn Semegen, (313) 935-7106, semegen@dwsd.org.

How Do We Know the Water is Safe to Drink?

Detroit Water and Sewerage Department facilities operate twenty-four hours a day, seven days a week. The treatment process begins with disinfecting the source water with chlorine to kill harmful microorganisms that can cause illness. Next, a chemical called Alum is mixed with the water to remove the fine particles that make the water cloudy or turbid. Alum causes the particles to clump together and settle to the bottom. Fluoride is also added to protect our teeth from cavities and decay.

The water then flows through fine sand filters called beds. These filters remove even more particles and certain microorganisms that are resistant to chlorine. Finally, a small amount of phosphoric acid and chlorine are added to the treated water just before it leaves the treatment plant. The phosphoric acid helps control the lead that may dissolve in water from household plumbing systems. The chlorine keeps the water disinfected as it travels through water mains to reach your home.

In addition to a carefully controlled and monitored treatment process, the water is tested for a variety of substances before treatment, during various stages of treatment, and throughout the distribution system. Hundreds of samples are tested each week in certified laboratories by highly qualified and trained staff. Our water not only meets safety and health standards but also ranks among the top 10 in the country for quality and value.

Additional Information

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Detected Contaminants Tables

These tables are based on tests conducted by DWSD in the year 2004 or the most recent testing done within the last five (5) calendar years. **They conduct many tests throughout the year; however, only tests that show the presence of a contaminant are shown here.** The table on the next page is a key to the terms used in the tables.

| Key to Detected Contaminants Tables | | |
|--|--|--|
| Symbol | Abbreviation for | Definition/Explanation |
| MCLG | Maximum Contaminant Level Goal | The level of contaminant in drinking water below which there is no known or expected risk to health. |
| MCL | Maximum Contaminant Level | The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| MRDLG | Maximum Residual Disinfectant Level Goal | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL | Maximum Residual Disinfectant Level | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| ppb | Parts per billion (one in one billion) | The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram. |
| ppm | Parts per million (one in one million) | The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram. |
| NTU | Nephelometric Turbidity Units | Measures the cloudiness of water. |
| TT | Treatment Technique | A required process intended to reduce the level of a contaminant in drinking water. |
| AL | Action Level | The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| n/a | Not applicable | |
| ≥ | More than or equal to | |

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's **Safe Drinking Water Hotline at (800-426-4791)**.

Northeast Water Treatment Plant 2004 Regulated Detected Contaminants Tables

| Contaminant | Test Date | Units | Health Goal MCLG | Allowed Level MCL | Level Detected | Range of Detection | Violation yes/no | Major Sources in Drinking Water |
|--|--------------|-------|---------------------|----------------------|----------------|--------------------|------------------|---|
| Inorganic Chemicals – Annual Monitoring at Plant Finished Water Tap | | | | | | | | |
| Fluoride | 8/17/2004 | ppm | 4 | 4 | 1.0 | n/a | No | Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Disinfectant Residuals and Disinfection By-Products – Monitoring in Distribution System | | | | | | | | |
| Total Trihalomethanes (TTHM) | Feb-Nov 2004 | ppb | n/a | 80 | 23.8 | 10.0-41.6 | No | By-product of drinking water chlorination |
| Haloacetic Acids (HAA5) | Feb-Nov 2004 | ppb | n/a | 60 | 17.0 | 6.2-36.1 | No | By-product of drinking water disinfection |
| Disinfectant (chlorine) Residual (ppm) | Jan-Dec 2004 | ppm | MRDGL 4 | MRDL 4 | 0.73 | 0.51-0.86 | No | Water additive used to control microbes |

| 2004 Turbidity – Monitored every 4 hours at Plant Finished Water Tap | | | |
|--|---|-------------------------|--|
| <u>Highest Single Measurement Cannot exceed 1 NTU</u> | <u>Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)</u> | <u>Violation yes/no</u> | <u>Major Sources in Drinking Water</u> |
| 0.24 NTU | 100% | No | Soil Runoff |
| Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system. | | | |

| 2004 Microbiological Contaminants – Monthly Monitoring in Distribution System | | | | | |
|--|------|---|-------------------------|------------------|---------------------------------------|
| Contaminant | MCLG | MCL | Highest Number Detected | Violation Yes/no | Major Sources in Drinking Water |
| Total Coliform Bacteria | 0 | Presence of Coliform bacteria > 5% of monthly samples | in one month – 0 | No | Naturally present in the environment. |
| <i>E. coli</i> or fecal coliform bacteria | 0 | A routine sample and a repeat sample are total coliform positive, and one is also fecal or <i>E. coli</i> positive. | entire year – 0 | No | Human waste and animal fecal waste. |

| Lead and Copper Monitoring at Customers' Tap | | | | | | | | |
|--|-----------|-------|---------------------|--------------------|------------------------------------|---------------------------|------------------|--|
| Contaminant | Test Date | Units | Health Goal MCLG | Action Level AL | 90 th Percentile Value* | Number of Samples Over AL | Violation Yes/no | Major Sources in Drinking Water |
| Lead | 2002 | ppb | 0 | 15 | 11.8 ppb | 1 | No | Corrosion of household plumbing system; Erosion of natural deposits. |
| Copper | 2002 | ppb | 1300 | 1300 | 186.7 ppb | 0 | No | Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives. |
| *The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met. | | | | | | | | |

| Regulated Contaminant | Treatment Technique | Running annual average | Monthly Ratio Range | Violation Yes/No | Typical Source of Contaminant |
|----------------------------|--|------------------------|---------------------|------------------|-------------------------------|
| Total Organic Carbon (ppm) | The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each month and because the level was low, there is no requirement for TOC removal. | | | | Erosion of natural deposits |

2004 Special Monitoring

| Contaminant | MCLG | MCL | Level Detected | Source of Contamination |
|--------------|------|-----|----------------|-----------------------------|
| Sodium (ppm) | n/a | n/a | 5 | Erosion of natural deposits |

Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

City of Detroit Public Water System
Regulated Contaminants that Required Monitoring but were *Not Detected*

**Synthetic Organic Contaminants Including Pesticides and Herbicide
(Test Date 2002 and 2003)**

| | |
|----------------------|----------------------------------|
| 2,4,5-TP (silvex) | Glyphosate |
| 2,4-D | Heptachlor epoxide |
| Alachlor | Heptachlor |
| Atrazine | Hexachlorobenzene |
| Carbofuran | Hexachlorocyclopentadiene |
| Chlordane | Lindane |
| Dalapon | Methoxychlor |
| Dibromochloropropane | Oxamyl (Vydate) |
| Dinoseb | PCBs (polychlorinated biphenyls) |
| Diquat | Pentachlorophenol |
| Endothall | Picloram |
| Endrin | Simazine |
| Ethylene Dibromide | Toxaphene |

Volatile Organic Contaminants (Test Date 2003-2004)

1,1,1-Trichloroethane
1,1,2-Trichloroethane
1,1-Dichloroethylene
1,2,4-Trichlorobenzene
1,2-Dichloroethane
1,2-Dichloropropane
1,2 dibromoethane
1,2,dibromo 3 chloropropane
Benzene
Carbon Tetrachloride
Chlorobenzene
Dichloromethane
cis-1,2-Dichloroethylene
o-Dichlorobenzene
p-Dichlorobenzene
ethyl benzene
Methylene Chloride
Styrene
Tetrachloroethylene
Toluene
trans-1,2-Dichloroethylene
Trichloroethylene
Vinyl Chloride
Total
xylenes

Inorganic Contaminants (Test Date 1999)

Antimony
Barium
Beryllium
Cadmium
Chromium
Mercury (inorganic)
Nickel
Nitrite (as nitrogen)
Selenium
Thallium

Inorganic Contaminants (Test Date 2004)

Arsenic

Radioactive Contaminants (Test Date 2001)

Beta/photon Emitters
Alpha Emitters

**City of Detroit Public Water System
2004**

Unregulated Contaminants that were Monitored and Not Detected

*Current regulations do not require monitoring for these contaminants however they are included in our routine monitoring program (Test dates 2003-2004)

Chemical

Dichlorobutane, 1-4
Fluorotrichloromethane
Hexachloroethane
Methyl Ethyl Ketone
Methyl Isobutyl Ketone
Methyl Tert-Butyl Ether (MTBE)
Monobromoacetic Acid
Tetrahydrofuran
2,4,5,-T
Acifluorfen
Ametryn
Bentazon
Bromacil
Butylate
Carboxin
Chlorothalonil
Cyanazine
Cycloate
Cyprazine
Dacthal
DDD, 4,4` -
DDE, 4,4` -
DDT,4,4` -
Diphenamid
Endosulfan, alpha
Endosulfan, beta
Endrin Aldehyde
Eptam
Hexachlorocyclohexane
Hexachlorocyclohexane (Beta-BHC)
Hexazinone
Methiocarb
Octachlorocyclopentene
Polybrominated Biphenyls (PBB)
Prometon
Pronamide
Propazine
Propoxur (Baygon)
Tebuthiuron
Terbacil
Trifluralin

Important Health Information

Lead

Since 1992, with the cooperation of many Royal Oak residents, DWSD has been testing homes with plumbing systems that may contribute lead to the household water supply. Our latest round of testing shows 0 out of the 11 homes tested has lead levels above the action level. If your home has a lead service line or piping that has lead soldered joints, you can take the following precautions to minimize your exposure to lead that may have leached into your drinking water from your pipes.

- Run your water for 30 to 60 seconds or until it feels cold. This practice should be followed anytime your water has not been used for more than 6 hours.
- Always use cold water for drinking, cooking or making baby formula.
- Use faucets and plumbing material that are either lead free or will not leach unsafe levels of lead into your water.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the **Safe Drinking Water Hotline at (800) 426-4791**.

People With Special Health Concerns

Some people may be more vulnerable to contaminants in drinking water than is the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the **Safe Drinking Water Hotline at (800-426-4791)**.

Cryptosporidium

Cryptosporidium is a disease-causing parasite that lives in the intestinal tract of many animals including dogs and cats. Symptoms of infection include diarrhea, abdominal cramps, headaches, nausea and vomiting. The disease is typically spread through contact with feces of an infected animal or person and consuming contaminated food or water. Cryptosporidium can be introduced into bodies of water by way of surface water runoff containing animal waste and sewage discharge. The Detroit Water and Sewerage Department has been testing for Cryptosporidium since 1994 and has not detected it in any of our source water supplies.

Questions:

Local Distribution: City of Royal Oak, Department of Public Works
(248) 246-3300

Southeastern Oakland County Water Supply System – Water Authority offices:
(248) 288-5150. Visit our web site at www.socwa.org.

Detroit Water and Sewerage Department – Water Quality Division at (313) 267-3629.

Michigan Department of Environmental Quality - Drinking Water and Radiological Protection
Division – 517-335-9216.

U.S. Environmental Protection Agency – Safe Drinking Water Hotline: (800) 426-4791

Water quality data for community water systems throughout the United States is available at:
www.waterdata.com.

Other Monitoring

In addition to testing we are required to perform, our water system voluntarily tests for hundreds of additional substances and microscopic organisms to make certain our water is safe and of the highest quality. If you are interested in a more detailed report, contact the DWSD Water Quality Division at (313) 267-3629.